

NR 210



State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES

Anthony S. Earl
Secretary

BOX 7921
MADISON, WISCONSIN 53707

IN REPLY REFER TO: _____

STATE OF WISCONSIN)
)
DEPARTMENT OF NATURAL RESOURCES) SS

RECEIVED
MAY 11 1977
2:40 pm
REVISOR OF STATUTES
BUREAU *Earl*

TO ALL TO WHOM THESE PRESENTS SHALL COME, GREETINGS:

I, Anthony S. Earl, Secretary of the Department of Natural Resources and custodian of the official records of said Department, do hereby certify that the annexed copy of Natural Resources Board Order No. EL-108-76b was duly approved and adopted by this Department on December 16, 1976. I further certify that said copy has been compared by me with the original on file in this Department and that the same is a true copy thereof, and of the whole of such original.

IN TESTIMONY WHEREOF, I have hereunto set my hand and affixed the official seal of the Department at Pyare Square Building in the Village of Shorewood Hills, this 9TH day of May, 1977.

Anthony S. Earl
Anthony S. Earl, Secretary

(SEAL)

STATE OF WISCONSIN NATURAL RESOURCES BOARD

.....
IN THE MATTER of repealing section NR 210.10(1) (d); .
renumbering section NR 210.10(1) (e); amending section .
NR 210.12; and repealing and recreating section NR .
210.10(1) (c) of the Wisconsin Administrative Code . EL-108-76b
pertaining to WPDES applications and sewage treatment .
works .
.....

ORDER OF THE STATE OF WISCONSIN NATURAL RESOURCES BOARD

REPEALING, RENUMBERING, AMENDING AND REPEALING & RECREATING RULES

Pursuant to the authority vested in the State of Wisconsin Natural Resources Board by sections 147.04(2) (a), (3) (a) and (4) (d), and 227.014(2) (a) and (c), Wisconsin Statutes, the State of Wisconsin Natural Resources Board hereby repeals, renumbers, amends and repeals and recreates rules as follows:

SECTION 1 - Section NR 210.10 (1) (c) is repealed and recreated to read:

(c) pH. The effluent pH shall be within the limits of 6.0 to 9.0 unless the treatment works:

1. Demonstrates that inorganic chemicals are not added as part of the treatment process, and
2. In the case of a publicly owned treatment works, demonstrates that contributions from industrial sources do not cause the pH of the effluent to be less than 6.0 or greater than 9.0.

SECTION 2 - Section NR 210.10 (1) (d) is repealed.

SECTION 3 - Section NR 210.10 (1) (e) is renumbered to be NR 210.10 (1) (d).

SECTION 4 - Section NR 210.12 is amended to read:

NR 210.12 Emergency power. (1) All treatment works subject to the provisions of this chapter shall by July 1, 1977, have either an alternate power source or standby generating units for treatment units and main lift stations to provide

at least primary clarification and disinfection at all times, or shall demonstrate to the department that adequate holding facilities exist to prevent the discharge of raw sewage from main lift stations and the treatment plant during periods of power outage.

(2) The department may require that treatment works discharging to critical stream segments provide an alternate power source or standby generating units sufficient to operate all treatment units at all times, or demonstrate to the department that adequate holding facilities exist to prevent the discharge of inadequately treated sewage during periods of power outage.

The foregoing rules were approved and adopted by the State of Wisconsin Natural Resources Board on December 16, 1976.

The rules contained herein shall take effect upon publication.

Dated at Madison, Wisconsin

9 May 1977

STATE OF WISCONSIN DEPARTMENT OF NATURAL RESOURCES

By

Anthony S. Earl

Anthony S. Earl, Secretary

(SEAL)