

H 62

STATE OF WISCONSIN)
) ss
DEPARTMENT OF HEALTH AND SOCIAL SERVICES)

TO ALL TO WHOM THESE PRESENTS SHALL COME, GREETINGS:

I, Manuel Carballo, Secretary of the Department of Health and Social Services and custodian of the official records of said department, do hereby certify that the amendment of the rules and regulations, relating to steel septic tanks were duly approved and adopted by this department on February 14, 1977.

I, further certify that to the best of my knowledge, my official representative, has compared said copy with the original on file in this department and that the same is a true copy thereof, and of the whole of such original.

IN TESTIMONY WHEREOF, I have hereunto set my hand and affixed the official seal of the department in the city of Madison, this 15th day of June, 1977.

Manuel Carballo
Manuel Carballo, Secretary
Department of Health & Social Services

SEAL

JUN 21 1977
12:40 pm
REVISOR OF STATUTES
BUREAU GSP

ORDER OF THE DEPARTMENT OF HEALTH & SOCIAL SERVICES ADOPTING RULES

Pursuant to authority vested in the Department of Health and Social Services in Chapter 39, Laws of 1975, and in accordance with Chapter 227, Wis. Stats., the following rules are hereby promulgated:

Section H 62.19(2)(a)17 is amended to read:

17. Steel septic tanks. For general tank design see section H 62.20 (4) (a) and (b) and H 62.19 (2) (a) 17. Steel tanks shall be fabricated of new, hot rolled commercial steel. The tanks including cover with rim, inlet and outlet collars and manhole extension collars shall be fabricated with welded joints in such manner as to provide structural stability and water tightness. Steel tanks shall be coated, inside and outside in compliance with U.L. Standard 70 Bituminous Coated Metal Septic Tanks. Any damage to the bituminous coating shall be repaired by recoating. The gauge of the steel shall be as follows:

Septic Tank Capacity

Tank Design

Vertical Cylindrical

500 thru 1,000 gallons-----	Bottom and sidewalls	14 ga	None
	Cover	12 ga	
	Baffles	12 ga	
1,001 thru 1,250 gallons---	Complete tank	10 ga	None
1,251 thru 1,500 gallons---	Complete tank	7 ga	None

Horizontal Cylindrical

500 thru 1,000 gallons-----	Complete tank	13 ga	54" dia
1,001 thru 1,500 gallons---	Complete tank	12 ga	64" dia
1,501 thru 2,500 gallons---	Complete tank	10 ga	76" dia
2,501 thru 9,000 gallons---	Complete tank	7 ga	76" dia
9,001 thru 12,000 gallons--	Complete tank	1/4" plate	None
12,001 or more gallons-----	Complete tank	5/16" plate	None

The rules contained herein shall take effect on August 1, 1977 as provided in Section 227.026(1), Wis. Stats., subject to the provisions of Section 14.06, Wis. Stats.

Manuel Carballo
Manuel Carballo, Secretary
Department of Health & Social Services

Dated June 15, 1977

SEAL