


PSC 185

CERTIFICATE



STATE OF WISCONSIN )  
 ) ss.  
 PUBLIC SERVICE COMMISSION )

TO ALL TO WHOM THESE PRESENTS SHALL COME, GREETINGS:

I, Lewis T. Mittness, Executive Secretary of the Public Service Commission, and custodian of the official records of said Commission, do certify that the annexed rules relating to the testing of new or rebuilt water meters were duly approved and adopted by this Commission on October 11, 1977.

I further certify that this copy of the rules has been compared by me with the original on file in this Commission and that the same is a true copy thereof, and of the whole of such rules.

IN TESTIMONY WHEREOF, I have hereunto set my hand and affixed the official seal of the Commission at the Hill Farms State Office Building in the City of Madison this 14th day of October 1977.

*Lewis T. Mittness*

\_\_\_\_\_  
 Lewis T. Mittness  
 Executive Secretary  
 PUBLIC SERVICE COMMISSION OF WISCONSIN

BEFORE THE  
PUBLIC SERVICE COMMISSION OF WISCONSIN

Testing of New or Rebuilt            )  
Water Meters                            )                   2-U-7039

ORDER OF THE PUBLIC SERVICE  
COMMISSION ADOPTING RULES

Pursuant to authority vested in the Public Service Commission by sections 196.02(3), 196.16, and 227.014, Wis. Stats., the Public Service Commission hereby amends and adopts rules as follows:

Wis. Adm. Code sec. PSC 185.75(1) is amended to read:

(1) Before use (new or rebuilt meters) or sample tested in accordance with PSC 185.751. (New material underlined.)

Wis. Adm. Code sec. PSC 185.751 is created to read:

PSC 185.751 Alternate sample-testing plan for "before use" test for 5/8, 3/4-, and 1-inch meters.

(1) This sample testing plan may be used only when the supplier tests and furnishes a test report for each new or remanufactured meter.

(2) Meters as received from the supplier shall be divided into lots of 36 or less. Each lot shall consist of meters of the same make, type and size.

(3) A random-selected sample of four meters from each lot shall be selected and tested.


(4) If any of the tested meters in a given lot fail to meet the accuracy requirements of PSC 185.65(2) for new meters, either the entire lot shall be rejected or the utility shall test all meters in the lot, rejecting or correcting those found to be inaccurate.

(5) Records shall be maintained showing the identification numbers of all meters in each lot and the test results for the meters tested.

The rules created herein shall take effect on the first day of the month following their publication in the Wisconsin Administrative Register, as provided in section 227.026(1) Wis. Stats.

Dated at Madison, Wisconsin October 11, 1977

By the Commission.

  
Lewis T. Mittness  
Lewis T. Mittness  
Executive Secretary