

Chapter Ind 41

SCOPE, GENERAL RULES, NEW AND EXISTING
INSTALLATIONS**PART I—SCOPE AND DEFINITIONS**

- Ind 41.01 Scope
- Ind 41.02 Definitions

PART II—GENERAL RULES

- Ind 41.03 Safety regulations
- Ind 41.04 Reporting accidents, repairs and alterations
- Ind 41.05 Notification of installation of boilers, pressure vessels and power piping.
- Ind 41.06 Identification of boilers and pressure vessels
- Ind 41.08 Certificate of competency as inspector
- Ind 41.10 Adoption of standards
- Ind 41.11 Boiler blow-down equipment
- Ind 41.12 Vessels supplied through pressure reducing valves
- Ind 41.13 Maintenance
- Ind 41.14 Inspection of new installations
- Ind 41.15 Manufacturer's data reports
- Ind 41.16 Low-water cutoff and water feeder

PART III—INSPECTIONS

- Ind 41.17 Inspection fees
- Ind 41.20 Periodic inspections required
- Ind 41.21 Exemptions from periodic inspections
- Ind 41.22 Preparation for internal inspection
- Ind 41.23 Insurance company inspections
- Ind 41.24 Inspections by cities
- Ind 41.25 Companies or corporations allowed to make inspections
- Ind 41.26 Reporting of inspections
- Ind 41.27 Inspection report forms
- Ind 41.28 Certificates of operation
- Ind 41.29 Condemnation

PART IV—NUCLEAR POWER PLANTS

- Ind 41.30 Installation registration
- Ind 41.35 Periodic inspections
- Ind 41.40 Welded repair
- Ind 41.45 Report of incidents

PART V—NEW INSTALLATIONS, ORIGINAL CONSTRUCTION

- Ind 41.50 A.S.M.E. code vessels
- Ind 41.51 Wisconsin special vessels
- Ind 41.52 U.S. Department of Transportation—Federal Highway Division
- Ind 41.53 Non-code vessels
- Ind 41.54 Multi-boiler installation
- Ind 41.55 Pressure gauges for air receivers

PART VI—EXISTING INSTALLATIONS

- Ind 41.60 Application
- Ind 41.61 Maximum allowable working pressures
- Ind 41.62 Code constructed vessels
- Ind 41.63 Pressure calculations for shells
- Ind 41.64 Pressure calculations for flat heads and flat surfaces
- Ind 41.65 Pressure calculations for dished heads
- Ind 41.66 Dished head restrictions
- Ind 41.67 Pressure calculation for furnaces and circular flues
- Ind 41.68 Boiler plate thickness
- Ind 41.69 Other methods of installing safety devices and other appliances
- Ind 41.70 Factor of safety
- Ind 41.71 Strength of materials
- Ind 41.72 Shearing strength of rivets
- Ind 41.73 Efficiency of joint
- Ind 41.74 Ligament between parallel tube holes
- Ind 41.75 Ligaments between diagonal tube holes
- Ind 41.76 Maximum pressure for cast iron boilers
- Ind 41.77 Safety or relief valves required on boilers
- Ind 41.78 Safety valves for low pressure steam, miniature and power boilers
- Ind 41.79 Water-relief valves for hot water boilers
- Ind 41.80 Thermometers for hot water boilers
- Ind 41.81 Water glass
- Ind 41.82 Gage cocks
- Ind 41.83 Water column piping
- Ind 41.84 Pressure gages
- Ind 41.85 Stop valves on pressure discharge outlets
- Ind 41.86 Steam mains
- Ind 41.87 Bottom blow-off or drain
- Ind 41.88 Feed pipe
- Ind 41.89 Combustion regulators for boilers
- Ind 41.91 Washout and inspection openings
- Ind 41.92 Manholes
- Ind 41.93 Maintenance
- Ind 41.94 Threaded openings
- Ind 41.95 Boiler setting and installation
- Ind 41.96 Access and firing doors
- Ind 41.97 Water tube boiler doors
- Ind 41.99 Pressure relief devices required for unfired pressure vessels

Note: Chapters Ind 41 and 42 as they existed on April 30, 1961 were repealed and new Chapters 41 and 42 were created effective May 1, 1961.

Register, May, 1978, No. 269
Boiler and Pressure Vessel Code

PART I
SCOPE AND DEFINITIONS

Ind 41.01 Scope. (1) The provisions of this code apply to boilers, pressure vessels and piping components associated with boilers in use at places of employment and in public buildings.

Note: Section 101.01 (2), Stats., provides that the phrase "place of employment" means and includes every place, whether indoors or out or underground and the premises appurtenant thereto where either temporarily or permanently any industry, trade or business is carried on, or where any process or operation, directly or indirectly related to any industry, trade or business, is carried on, and where any person is, directly or indirectly, employed by another for direct or indirect gain or profit, but does not include any place where persons employed in private domestic service which does not involve the use of mechanical power or farming. "Farming" includes those activities specified in section 102.04 (3), and also includes the transportation of farm products, supplies or equipment directly to the farm by the operator of said farm or his employes for use thereon, if such activities are directly or indirectly for the purpose of producing commodities for market, or as an accessory to such production. When used with relation to building codes, "place of employment" does not include a previously constructed building used as a community-based residential facility as defined in section 60.01 (1) which serves 20 or fewer unrelated residents, except for the purposes of section 101.11.

(2) Vessels used for the storage and transportation of flammable liquids, liquefied petroleum gas, anhydrous ammonia, and refrigerants shall be subject to the provisions of this code, unless covered by other Wisconsin administrative codes or federal codes.

History: Cr. Register, April 1961, No. 64, eff. 5-1-74; r. and recr., Register, May, 1974, No. 221, eff. 6-1-74; am. (1), Register, May, 1978, No. 269, eff. 6-1-78.

Ind 41.02 Definitions. The definitions of this section shall be applicable throughout this code.

(1) **ASME BOILER AND PRESSURE VESSEL CODES** are those published by the American Society of Mechanical Engineers and will hereinafter be referred to as ASME.

(1a) **Alteration.** For the purposes of this code, "alteration" means a change in a boiler or pressure vessel that substantially alters the original design requiring consideration of the effect of the change on the original design. It is not intended that the addition of nozzles smaller than an unreinforced opening size be considered an alteration. (Also see "repair.")

(2) **BOILER.** A closed vessel intended for use in heating water or for the application of heat to generate steam or other vapor to be used externally to itself.

(a) **Low pressure boiler.** A boiler on which the safety valves are set at pressures not exceeding 15 psig.

(b) **Miniature boiler.** A miniature boiler is a power boiler or high temperature water boiler which does not exceed any of the following limits:

1. 16 inches inside diameter of shell;
2. 20 square feet heating surface (not applicable to electric boilers);
3. 5 cubic feet gross volume exclusive of casing and insulation;
4. 100 psi maximum allowable working pressure.

(c) *Portable boiler.* An internally fired boiler primarily intended for temporary location and whose construction and usage is obviously of a portable nature.

(d) *Power boiler.* A power boiler is a boiler in which steam or other vapor is generated at a pressure of more than .15 psig.

(e) *High temperature water boiler.* A high temperature water boiler is a water boiler intended for operation at pressures in excess of 160 psig or temperatures in excess of 250° F.

(3) **CERTIFICATE OF COMPETENCY.** A certificate issued to a boiler or pressure vessel inspector by the department.

(4) **CONDEMNED.** A boiler or pressure vessel declared to be unsafe and has an applied stamping designating its condemnation.

(5) **DEPARTMENT.** Means the department of industry, labor and human relations.

(5m) **ENFORCEMENT AUTHORITY.** Enforcement authority means the department, which is empowered to formulate definitions, rules and regulations for the safe construction, installation, inspection, operation, maintenance, repair and alteration of boilers and pressure vessels in this state.

(6) **EXISTING INSTALLATION.** Boiler and pressure vessels placed in operation or contracted for prior to January 1, 1957. (See part VI.)

(7) **EXTERNAL INSPECTION.** One made while boiler or vessel is in operation.

(8) **FUSION WELDING.** The melting together of filler metal and base metal, or of base metal only, which results in coalescence.

(8c) **HOT WATER STORAGE TANK.** A hot water storage tank is a tank used to store water that is heated indirectly by a circulating water heater or by steam or hot water circulating through coils or other heat exchange methods internal or external to the tank.

(9) **HOT WATER HEATING BOILER AND HOT WATER SUPPLY BOILER.** A boiler completely filled with water that furnishes hot water to be used externally to itself at pressures not exceeding 160 psig or at temperatures not exceeding 250° F. (A boiler exceeding either of these limits shall be classified as a power boiler.)

(10) **INSPECTOR, AUTHORIZED OR QUALIFIED.** (a) *Field inspector.* A boiler or pressure vessel inspector who holds a valid certificate of competency issued by the department.

(b) *Shop inspector.* A boiler or pressure vessel inspector who is holding the necessary commissions and employed by a city or a state which has adopted the ASME boiler and pressure vessel code, or who is employed by an insurance company and who, when performing shop inspections in Wisconsin, holds a certificate of competency issued by the department.

(11) **INTERNAL INSPECTION.** One made when the boiler or pressure vessel is shut down and handholes and manholes or other inspection openings are opened or removed for inspection of the interior as required by the inspector.

- (11j) **JURISDICTIONAL AUTHORITY.** See "enforcement authority."
- (12) **NON-STANDARD BOILER OR NON-STANDARD PRESSURE VESSEL.** One not bearing a valid Wisconsin stamping, nor the ASME stamping, nor the National Board stamping, nor the U.S. department of transportation stamping, nor the stamping of the API-ASME, nor any stamping authorized by other applicable codes.
- (13) **OWNER OR USER.** Any person, firm, or corporation owning or operating a boiler or pressure vessel.
- (13p) **POWER PIPING.** Power piping means any steam piping system having an operating pressure in excess of 15 psig or any hot water piping system subject to temperatures in excess of 250° F.
- (13t) **PRESSURE-TEMPERATURE RELIEVING VALVE.** A pressure-temperature relieving valve is an automatic relieving device actuated by the static pressure upstream of the valve which opens further with increase in the pressure over the opening pressure, or by the temperature of the fluid. It is used primarily for liquid service.
- (14) **PRESSURE VESSEL.** A pressure vessel is a container for the containment of pressure, either internal or external. This pressure may be obtained from an external source or by the application of heat from a direct or indirect source, or any combination thereof.
- (14g) **RELIEF VALVE.** A relief valve is an automatic pressure-relieving device actuated by the static pressure upstream of the valve which opens further with the increase in pressure over the opening pressure. It is used primarily for liquid service.
- (15) **REPAIR.** Repair is work necessary to return a boiler or pressure vessel to a safe operating condition. (Also see "alteration.")
- (15g) **RUPTURE DISK.** A rupture disk is a nonmechanical overpressure relief device that releases pressure when its preestablished rating is attained.
- (15m) **SAFETY RELIEF VALVE.** A safety relief valve is an automatic pressure-actuated relieving device suitable for use either as a safety valve or relief valve, depending upon application.
- (15n) **SAFETY VALVE.** A safety valve is an automatic pressure-relieving device actuated by the static pressure upstream of the valve and characterized by full-opening pop action. It is used for gas or vapor service.
- (16) **SECONDHAND VESSEL.** A boiler or pressure vessel when both location and ownership have been changed subsequent to the original installation.
- (23) **WATER HEATER.** A water heater is a closed vessel in which water is heated by the combustion of fuels, electricity, or any other source and withdrawn for use external to the system at pressures not exceeding 160 psig and shall include the apparatus by which heat is generated and all controls and devices necessary to prevent water temperatures from exceeding 210° F.

Note: For further explanation of definitions, see the current edition of the ASME Code—Section VIII—Scope.

Register, May, 1978, No. 269
Boiler and Pressure Vessel Code

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; am. (2) (b), (7), (10), Register, January, 1966, No. 121, eff. 2-1-66; am. (3), (4), (8) (a) and (b), (9), (10), (11), (12), (13), (14), (15), and cr (16), Register, October, 1970, No. 178, eff. 11-1-70; r. and recr. Register, May, 1974, No. 221, eff. 6-1-74; cr. (Intro.), (1) (a), (2) (e), (5m), (8t), (11j), (13p), (13t), (14g), (15g), (15m), (15n), and (23), am. (2) (b) and (d), r. and recr. (14) and (15), Register, May, 1978, No. 269, eff. 6-1-78.

PART II GENERAL RULES

Ind 41.03 Safety regulations. (1) No boiler or pressure vessel shall be operated at a pressure in excess of the maximum operating pressure stated on its current certificate of operation.

(2) No unauthorized person shall remove or tamper with any connected safety device nor shall any person adjust a connected safety valve to a greater relieving pressure than that allowed for the vessel as stated on its current certificate of operation.

(3) Boiler and pressure vessels shall be so installed that there will be sufficient room between the vessel and any ceiling, wall, partition, or floor to facilitate the connection and operation of valves, pipes, and other appurtenances and shall be installed in a manner that will not block any inspection opening.

Note: To assure proper installation, alteration, or repair of a boiler or pressure vessel, it may be necessary to comply with applicable Wisconsin Administrative Code sections in addition to the Wisconsin Boiler and Pressure Vessel Code. Some of the Wisconsin Code sections to be considered are as follows:

Section Ind 64.09 (combustion air intake requirements)

Section Ind 64.47 (metal smoke stack requirements)

Section Ind 54.14, 55.29, 56.15, 57.20 and 60.25 (boiler room requirements)

Section Ind 69.01 (fee schedule)

Section Ind 64.20 (1) (safety fuel burners)

Wisconsin Administrative Codes may be obtained by contacting State Department of Administration, Document Sales and Distribution, 202 So. Thornton Ave., Madison, Wis. 53702.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; am. (3), Register, January, 1966, No. 121, eff. 2-1-66; am., Register, February, 1971, No. 182, eff. 3-1-71.

Ind 41.04 Reporting accidents, repairs and alterations. (1) Whenever a boiler or pressure vessel fails and causes injury to any person, the owner or user shall report the facts involved to the department within the following 24 hours. The owner or user shall not remove or disturb the boiler or pressure vessel or any of its parts nor permit any such removal or disturbance prior to receiving authorization from the department, except for the purpose of saving human life or further property damage.

(2) The owner or user shall report any repairs or alterations of a boiler or pressure vessel as required in chapter Ind 42. The owner or user shall also report conversions to other fuels.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; am. Register, February, 1971, No. 182, eff. 3-1-71; r. and recr., Register, May, 1974, No. 221, eff. 6-1-74; am. (2), Register, May, 1978, No. 269, eff. 6-1-78.

Register, May, 1978, No. 269
Boiler and Pressure Vessel Code

Ind 41.05 Notification of installation of boilers, pressure vessels and power piping. (1) **BOILER OR PRESSURE VESSEL INSTALLATION NOTIFICATION.** Installing contractors* shall notify the department of the installation of any new or used boiler or pressure vessel before the operation of such.

(a) Notification shall:

1. Be by telephone or in writing.
2. Include boiler (s) location, type (power heating, miniature, etc.) and name plate data.
3. Include pressure vessel location, name plate data and size.

(b) Exceptions:

1. Notification is not required for new or used boilers or pressure vessels exempted in section Ind 41.21.
2. Notification to the department is not required for installations in cities of the first class if the appropriate city official has been notified.

(2) **POWER PIPING INSTALLATION REGISTRATION.** The installing contractor* of any power piping system shall file an installation registration form with the department or with the city if installed in a city of the first class. (See Form SB-5204 for an example of information required on the registration form.)

*Note: Owners or users making their own installations will be considered installing contractors.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; am. Register, February, 1971, No. 182, eff. 3-1-71; r. and recr., Register, May, 1974, No. 221, eff. 6-1-74; r. and recr. Register, May, 1978, No. 269, eff. 6-1-78.

Ind 41.06 Identification of boilers and pressure vessels. (1) The owner or user of a boiler or pressure vessel shall number each vessel in some permanent manner and in an accessible location.

(2) Boilers and pressure vessels subject to periodic inspections (see Ind 41.20) shall be identified by a registration number supplied by the department. The registration number shall be affixed by an authorized inspector. The state tag shall be attached to the vessel at a location which can be easily viewed.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; r. and recr. Register, February, 1971, No. 182, eff. 3-1-71; am. (2), Register, May, 1974, No. 221, eff. 6-1-74.

POWER PIPING
 INSTALLATION REGISTRATION
 SB-5204

STATE OF WISCONSIN
 DEPARTMENT OF INDUSTRY, LABOR AND HUMAN RELATIONS
 SAFETY AND BUILDINGS DIVISION

Complete appropriate portion.

Installing contractor shall prepare this form in triplicate and distribute as follows:
 White - Send to Dept. of Industry, Labor & Human Relations, Safety & Buildings Division, P.O. Box 7946, Madison, Wisconsin 53707, or City of Milwaukee, if applicable.
 Yellow - Send to owner.
 Pink - Retain for file.

Description of system

Name of user or owner			Location of installation		
Street Address					
City	State	Zip			
Safety valve settings — power source		Capacity	P S I C		
1.			Maximum allowable pressure		
2.			Test pressure		
3.			Date tested		
Name of installing contractor	Street address	City	State	Zip	
I certify this system was installed and tested in accordance with Ind 41.56 of the Wisconsin Administrative Code.					
Date installation completed	Signature of installer	Title	Date registered		

Register, May, 1978, No. 269
 Boiler and Pressure Vessel Code

Ind 41.08 Certificate of competency as inspector. (1) **CERTIFICATE REQUIRED.** An inspection report covering a boiler or pressure vessel may be recognized and accepted only when the inspector holds a valid certificate of competency issued by the department.

(2) **ELIGIBILITY.** (a) The applicant for a certificate of competency as a boiler or pressure vessel inspector shall be an employe of the state, a municipality, an insurance company, or a corporation or company authorized to make its own inspections.

(b) The applicant shall have had at least 3 years of experience in one or more of the following endeavors:

1. Construction, repair or inspection of high pressure boilers or pressure vessels; or

2. Operating engineer in charge of high pressure boilers or pressure vessels.

(c) A degree in mechanical engineering may be accepted as the equivalent of 2 years practical experience.

(d) The applicant's employer shall certify that applicant's statement of experience is correct.

(3) **APPLICATIONS AND RENEWALS.** (a) Fees for examination and reciprocal certificates of competency shall be submitted with applications and in the amount specified in Wis. Adm. Code chapter Ind 69.

(b) Renewal fees shall be submitted with the request for renewal and in the amount specified in chapter Ind 69.

(c) A request for renewal shall be filed with the department on or before January 1 of the calendar year for which the certificate is to be valid.

(d) Applications for examinations and applications for renewals by employes of the state and employes of the city of Milwaukee require no fee.

(4) **EXAMINATIONS.** (a) Certificates of competency for a boiler or pressure vessel inspector may be issued by the department to eligible applicants passing the examinations prescribed by and conducted by the department.

(b) Holders of certificates, who do not apply for renewal in any 3 year period may be required to pass a scheduled examination.

(5) **ANNULMENTS AND REVOCATIONS.** (a) A certificate becomes invalid when the holder terminates employment with the employer of record at the time of issue. A renewal may be obtained under the provisions of this section provided applicant meets eligibility requirements.

(b) A certificate may be annulled or revoked when incompetency or negligence is determined after investigation.

(6) **RECIPROCAL COMMISSIONS.** (a) A reciprocal certificate of competency may be granted by the department to a boiler or pressure vessel inspector under the following conditions:

1. The inspector shall be employed by a boiler insurance company licensed to do business in Wisconsin. The boiler insurance company shall make the application for a reciprocal commission to the department.

2. The inspector shall hold a commission issued by the National Board of Boiler and Pressure Vessel Inspectors or a certificate of competency from a city or state which has adopted the A.S.M.E. Boiler and Pressure Vessel Code and which holds a written examination similar to that required by Wisconsin.

History: Cr. Register, April, 1961, No. 84, eff. 5-1-61; r. and recr. Register, February, 1971, No. 182, eff. 3-1-71; am. (1), (3) (c), (4) (a), (6) (a) 1. and 3., Register, May, 1974, No. 221, eff. 6-1-74; am. (2) (b) and (5) (a), r. (6) (a) 3, Register, May, 1978, No. 269, eff. 6-1-78.

Ind 41.10 Adoption of standards. (1) The standards, amendments and errata issued by the American Society of Mechanical Engineers as listed in table 41.10-A are hereby incorporated by reference into this code.

(2) Pursuant to section 227.025, Wisconsin Statutes, consent has been granted to incorporate by reference the rules contained in the standards, amendments and errata listed in table 41.10-A.

(a) Copies are on file in the offices of the department, the secretary of state and the revisor of statutes.

(b) Copies may be procured for personal use from the American Society of Mechanical Engineers, United Engineering Center, 345 East 47th St., New York, New York 10017.

TABLE 41.10-A

			As amended by Summer Addenda issued June 30th and Winter Addenda issued December 31st of each respective year: S-Summer; W-Winter.		
			1974	1975	1976
1. Section	I	Power Boilers, 1974 Edition	S W	S W	S
2. Section	II	Material Specifications, 1974 Edition			
	a.	Part A — Ferrous Material	S W	S W	S
	b.	Part B — Nonferrous Material	S W	S W	S
	c.	Part C — Welding Rods, Electrodes, and Filler Metals	—	S W	S
3. Section	III	Nuclear Power Plant Components, Division 1, 1974 Edition			
	a.	Subsection NA — General Requirements	S W	S W	S
	b.	Subsection NB — Class 1 Components	S W	S W	S
	c.	Subsection NC — Class 2 Components	S W	S W	S
	d.	Subsection ND — Class 3 Components	S W	S W	S
	e.	Subsection NE — Class MC Components	S W	S W	S
	f.	Subsection NF — Components Supports	— W	S W	S
	g.	Subsection NG — Core Support Structures	S W	S W	S
4. Section	IV	Heating Boilers, 1974 Edition	S W	S W	S
5. Section	V	Nondestructive Examination, 1974 Edition	S W	S W	S
6. Section	VIII	Pressure Vessels, 1974 Edition			
	a.	Division 1	S W	S W	S
	b.	Division 2	S W	S W	S
7. Section	IX	Welding and Brazing Qualifications, 1974 Edition	S W	S W	S
8. Section	X	Fiberglass Reinforced Plastic Pressure Vessels, 1974 Edition	S W	S W	—
9. Section	XI	Rules for Inservice Inspection of Nuclear Power Plant Components, 1974 Edition	S W	S W	S

History: Cr. Register, May, 1974, No. 221, eff. 6-1-74; r. and recr. Register, April, 1975, No. 232, eff. 6-1-75; r. and recr. table Register, May, 1976, No. 245, eff. 6-1-76; r. and recr. table, Register, March, 1977, No. 255, eff. 4-1-77.

Ind 41.11 Boiler blow-down equipment. (1) The blow-down from a boiler or boilers that enters a sewer system or blow-down which is considered a hazard to life or property shall pass through some form of blow-off equipment that will reduce pressure and temperature as required hereinafter.

(2) The temperature of the water leaving the blow-off equipment shall not exceed 140 F.

(3) The pressure of the blow-down leaving any type of blow-off equipment shall not exceed 5 psi.

(4) The blow-off piping and fittings between the boiler and the blow-off tank shall comply with sections Ind 41.50 and Ind 41.51 of this code.

(5) The tank shall be designed in accordance with sections Ind 41.50 and Ind 41.51 of this code for a working pressure of at least one-fourth the maximum working pressure of the boiler to which it is connected.

Register, May, 1978, No. 289
Boiler and Pressure Vessel Code

(6) All blow-off equipment, except centrifugal blow-down separators, shall be fitted with openings to facilitate cleaning and inspection and shall have:

- (a) A pressure gauge graduated from 0-25 psi,
- (b) A thermometer well located near the water outlet connection and in contact with the retained water in the tank.
- (c) A gauge glass at least ½ inch in diameter. The lower connection to the glass shall be at a point about 6 inches below the water line; the upper connection about 6 inches above,
- (d) A drain connection at least 2-inch standard pipe size,
- (e) Connections designed so that freezing will not close the inlet, the outlet, or the vent,
- (f) Vent piping, full size, piped to the outside atmosphere and discharged to a safe location.

Note: Blow-off equipment designed in accordance with the boiler blow-off equipment code issued by the National Board of Boiler and Pressure Vessel Inspectors, 1973 edition, will meet the requirements of this section. Other methods of designing blow-off equipment may be used if approved by the department.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; r. and recr. (6), Register, May, 1974, No. 221, eff. 8-1-74.

Ind 41.12 Vessels supplied through pressure reducing valves. (1)
The following formula shall be used for determining the sizes of safety and relief valves on pressure vessels such as pressure cookers, indirect hot water heaters, equipment in heating systems, etc., which are supplied through pressure reducing valves from boilers carrying a higher steam pressure. Where a pressure reducing valve is supplied by a boiler, the capacity of the safety valve or valves on the low pressure side of the system need not exceed the capacity of the boiler.

$$RVC = \frac{1}{2} \times OC \times VSPA$$

Where RVC = relief valve capacity, lbs. of steam per hour.

OC = orifice capacity, lbs. of steam per hour per sq. in. (See Table 1.)

VSPA = valve size pipe area, sq. in. (See Table 2.)

TABLE 1. ORIFICE RELIEVING CAPACITIES, POUNDS PER SQUARE INCH

Outlet pres. psig	Pressure-reducing valve inlet pressure, psig															
	400	350	300	250	200	175	150	125	100	85	75	60	50	40	30	25
250.....	21000	17100	10800	—	—	—	—	—	—	—	—	—	—	—	—	—
200.....	21350	18250	15350	10900	—	—	—	—	—	—	—	—	—	—	—	—
175.....	21350	18250	16000	12800	7250	—	—	—	—	—	—	—	—	—	—	—
150.....	21350	18250	16200	13400	9540	6750	—	—	—	—	—	—	—	—	—	—
125.....	21350	18250	16200	13600	10800	8780	6220	—	—	—	—	—	—	—	—	—
110.....	21350	18250	16200	13600	11000	9460	7420	4550	—	—	—	—	—	—	—	—
100.....	21350	18250	16200	13600	11000	9760	7970	5630	—	—	—	—	—	—	—	—
85.....	21350	18250	16200	13600	11000	9760	8480	6640	4070	—	—	—	—	—	—	—
75.....	21350	18250	16200	13600	11000	9760	8480	7050	4980	3150	—	—	—	—	—	—
60.....	21350	18250	16200	13600	11000	9760	8480	7200	5750	4540	3520	—	—	—	—	—
50.....	21350	18250	16200	13600	11000	9760	8480	7200	5920	5000	4230	2680	—	—	—	—
40.....	21350	18250	16200	13600	11000	9760	8480	7200	5920	5140	4630	3480	2470	—	—	—
30.....	21350	18250	16200	13600	11000	9760	8480	7200	5920	5140	4630	3860	3140	2210	—	—
25.....	21350	18250	16200	13600	11000	9760	8480	7200	5920	5140	4630	3860	3340	2580	1485	—
15.....	21350	18250	16200	13600	11000	9760	8480	7200	5920	5140	4630	3860	3340	2830	2320	1800
10.....	21350	18250	16200	13600	11000	9760	8480	7200	5920	5140	4630	3860	3340	2830	2320	2060
5.....	21350	18250	16200	13600	11000	9760	8480	7200	5920	5140	4630	3860	3340	2830	2320	2060

Note: The following formulas shall be used in connection with this table to calculate the required relieving capacity of safety valves installed on the low-pressure side of pressure-reducing valves. Use the formula that requires the larger relieving capacity.

$$W = \frac{1}{2} AC \text{ or } W = \frac{1}{4} A^2 C$$

where: W=required safety valve relieving capacity.
 A=internal area of the pipe size of the pressure-reducing valve (use pipe areas of Table 2).
 A'=internal area of the pipe size of the by-pass line around the pressure-reducing valve.
 C=orifice relieving capacity, pounds of steam per hour per square inch for the given inlet and outlet pressures of the pressure-reducing valve (from this Table).

Register May 1978, No. 269
Boiler and Pressure Vessel Code

TABLE 2.—INTERNAL PIPE AREA

Nominal pipe size, inches	STANDARD		
	Actual internal diameter, inches	Approx. internal diameter, inches	Approx. internal area, square inches
3/8	0.675	0.49	0.19
1/2	0.840	0.62	0.30
3/4	1.050	0.82	0.53
1	1.315	1.05	0.86
1 1/4	1.660	1.38	1.50
1 1/2	1.900	1.61	2.04
2	2.375	2.07	3.36
2 1/2	2.875	2.47	4.78
3	3.5	3.07	7.39
3 1/2	4.0	3.55	9.89
4	4.5	4.03	12.73
5	5.563	5.05	19.99
6	6.625	6.07	28.89
8	8.625	8.07	51.15
10	10.750	10.19	81.55
12	12.750	12.09	114.80

Note: In applying these rules, the area of the pipe is always based upon standard weight pipe and the inlet size of the pressure-reducing valve.

(a) The following formula shall be used to determine the steam flow rate through the bypass when pressure reducing valves are arranged with a valved bypass which also acts as a potential steam source hazard in case the bypass is left open.

$$RVC = \frac{1}{2} \times OC \times BPA.$$

Where RVC = relief valve capacity, lbs. of steam per hour.

OC = orifice capacity, lbs. of steam per hour per square inch. (See Table 1.)

BPA = bypass pipe area, sq. inch. (See Table 2.)

(b) The larger of the relief valve capacities calculated by the formulas in subsections Ind 41.12 (1) and (1) (a) shall be used for selecting the relief valve for the vessel.

Note: Example. Suppose a high pressure boiler operating at 125 psi distributes steam to a series of 40 psi ASME constructed retorts through a 1 1/2 inch size pressure reducing valve provided with a glove-valved 1 inch bypass. Determine the proper ASME relief valve protection for the retorts. Utilizing data in tables and the first of the 2 formulas above:

$$W = \frac{1}{2} \times 7200 \times 2.04 = 4896 \text{ lbs. steam per hour.}$$

Checking the bypass steam flow according to the second formula gives:

$$W = \frac{1}{2} \times 7200 \times 0.86 = 3100 \text{ lbs. steam per hour.}$$

The potential steam flow through the pressure reducing valve is 4896 lbs. per hour rated capacity or

$$4896 \times 1000 \text{ or } 4.896.000 \text{ BTU per hour.}$$

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; am. Register, January, 1966, No. 121, eff. 2-1-66; r. and recr. (1) and Table 1, Register, February, 1971, No. 182, eff. 3-1-71; r. (1) second "Note" following Table 2 including referenced formulas that follow this note and cr. (1) (a) and (b), Register, May, 1971, No. 185, eff. 6-1-71.

Register, May, 1978, No. 269
Boiler and Pressure Vessel Code

Ind 41.13 Maintenance. (1) All boilers shall be installed and maintained in such a manner as to prevent excessive corrosion and deterioration.

(2) The inspector shall note conditions during internal inspection, external inspection, or hydrostatic pressure test and shall order such changes or repairs as will place the boiler in a safe working condition.

Note: Sections VI and VII, ASME Boiler and Pressure Vessel Code. "Recommended Rules for Care and Operating of Heating Boilers" and "Recommended Rules for Care of Power Boilers" are excellent guides for boiler owners and operators.

History: Cr. Register, February, 1971, No. 182, eff. 3-1-71.

Ind 41.14 Inspection of new installations. (1) A new installation of a new or used boiler or pressure vessel shall be inspected by the department before it is placed in operation unless one of the following conditions are met:

(a) The boilers or pressure vessels are exempt from periodic inspections in Ind 41.21.

(b) The boilers or pressure vessels are installed in a city of the first class and inspections are made by the city, wherein the city shall keep a record of such inspections and shall submit a copy to the department.

(c) The installation is inspected by an Authorized Inspector who shall file an inspection report with the department and shall affix the Wisconsin registration number as required in section Ind 41.06.

History: Cr. Register, May, 1974, No. 221, eff. 6-1-74; am. (1) (Intro.) and cr. (1) (c), Register, May, 1978, No. 269, eff. 6-1-78.

Ind 41.15 Manufacturer's data reports. The owner or user shall retain the manufacturer's data reports, except data reports for boilers and pressure vessels exempt from ASME code construction requirements. See section Ind 41.50.

History: Cr. Register, May, 1974, No. 221, eff. 6-1-74; r. and recr. Register, May, 1978, No. 269, eff. 6-1-78.

Ind 41.16 Low-water cutoff and water feeder. (1) Every automatically fired power boiler which does not have a full-time attendant and every automatically fired low-pressure steam boiler shall be equipped with an automatic low-water fuel cutoff or other device which will perform a similar function, so located as to automatically cut off the fuel supply when the surface of the water falls to the lowest safe water line. If a water-feeding device is installed, it shall be so constructed that the water inlet valve cannot feed water into the boiler through the float chamber and so located as to supply requisite feed water. The lowest safe water line shall be not lower than the lowest visible part of the water glass.

(2) Designs embodying a float and float bowl, or probe controls installed in a bowl or chamber externally to the boiler shall have a vertical straightway valved drain pipe at the lowest point in the water equalizing pipe connections by which the bowl or chamber and the equalizing pipe can be flushed and the device tested.

Note: See section Ind 41.54 for hot water heating boilers.

History: Cr. Register, May, 1974, No. 221, eff. 6-1-74.

Register, May, 1978, No. 269
Boiler and Pressure Vessel Code

**PART III
INSPECTIONS**

Ind 41.17 Inspection fees. Each inspection, test, or service performed by the department shall be paid for at rates established in Chapter Ind 69, Fee Schedule. (The owner is responsible for the payment of fees.)

History: Cr. Register, May, 1974, No. 221, eff. 6-1-74.

Ind 41.20 Periodic inspections required. (1) **ALL INSPECTIONS.** The authorized inspectors of the department, upon presenting appropriate credentials to the owner, operator, or agent in charge, are authorized—

(a) To enter without delay and at reasonable times any factory, plant, establishment, construction site, or other area, workplace or environment where work is performed by an employee of an employer; and

(b) To inspect and investigate during regular working hours and at other reasonable times, and within reasonable limits and in a reasonable manner, any such place of employment and all pertinent conditions, structures, machines, apparatus, devices, equipment, and materials therein, and to question privately any such employer, owner, operator, agent or employee.

(2) **CONTACTING REPRESENTATIVE.** The inspector before making an inspection shall contact a representative of the employer and a representative authorized by the employees who shall be given an opportunity to accompany the inspector during the physical inspection of any workplace under subsection (1) for the purpose of aiding such inspection.

(a) Where there is no authorized employee representative, the inspector shall consult with a reasonable number of employees concerning matters of health and safety in the workplace.

Note: The department policy is not to give advance notice, but in the scheduling and in the act of inspecting it may not always be possible to avoid advance notice or to obtain accompaniment as, for example, inside boilers or in precarious locations of elevator installations, but otherwise these rules will be diligently observed.

(3) **INSPECTION OF BOILERS.** Except as regulated in sections Ind 41.20 (5) and Ind 41.21, boilers shall be subjected to either a regular internal or external inspection at least once every 12 months by a qualified inspector.

(a) *When internal inspection is not possible.* Where an internal inspection is not possible because of the construction of the boiler, an external inspection will be acceptable.

(4) **INSPECTION OF PRESSURE VESSELS.** Except as regulated in section Ind 41.21, pressure vessels shall be subjected to a regular internal or external inspection at least once every 36 months by a qualified inspector.

(5) **INSPECTION OF LOW PRESSURE STEAM AND HOT WATER HEATING BOILERS.** Except as regulated in section Ind 41.21, low pressure steam and hot

water heating boilers shall be subjected to a regular external or internal inspection at least once every 36 months by a qualified inspector.

Note: Extension of period between inspections. If operating conditions require, longer periods between inspections of boilers or pressure vessels may be approved by the department upon a written request for an extension.

Note: For inspection fees, see Wis. Adm. Code chapter Ind 69, Fee Schedule.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; am. (2), (3), (4), Register, October, 1970, No. 178, eff. 11-1-70; renum. (1), (2), (3), (4) to be (3), (4), (5) and (6) and cr. (1) and (2), Register, April, 1973, No. 208, eff. 5-1-73; r. and recr. (3), (4), (5) and r. (6), Register, May, 1974, No. 221, eff. 6-1-74; am. (2) (intro.), (4) and (5), Register, May, 1978, No. 269, eff. 6-1-78.

Ind 41.21 Exemptions from periodic inspections. (1) The following will not be subject to periodic inspection:

(a) Boilers or pressure vessels which receive regular inspections by United States government inspectors.

(b) Steam boilers having an internal or external operating pressure not exceeding 15 psig with an input not exceeding 500,000 Btu per hour and hot water heating boilers having an operating pressure not exceeding 30 psig with an input not exceeding 500,000 Btu per hour, all of which are located in buildings other than apartment buildings.

(c) Heating boilers, which are either steam boilers having an internal or external operating pressure not exceeding 15 psig or hot water heating boilers having an operating pressure not exceeding 30 psig and located in private residences or in apartment buildings having less than 6 living units.

(d) Expansion tanks for hot water heating boilers having an operating pressure of less than 50 psig with no limitation on size.

(e) Boilers used exclusively for agricultural purposes.

(f) Miniature boilers.

(g) Pressure vessels having an inside diameter not exceeding 6 inches with no limit on pressure.

(h) Pressure vessels having a volume of less than 5 cubic feet and an operating pressure of less than 250 psi.

(i) Pressure vessels with a volume of less than 1-1/2 cubic feet with no limit on pressure.

(j) Pressure vessels having an internal or external operating pressure of not more than 15 psig with no limitations on size.

(k) Hot water supply boilers, water heaters and hot water storage tanks.

(l) Vessels used for the storage or processing cold water, including those with air cushions.

(m) Pressure vessels which are used in accordance with the regulations of the U.S. department of transportation.

Register, May, 1978, No. 269
Boiler and Pressure Vessel Code

(2) EXCEPTION. In individual cases, the boilers and pressure vessels exempted in (1) will be subject to inspection by or on order of the department upon complaint of any person or upon initiative of the department when there is reasonable cause to suspect that the construction, installation, maintenance or operation of the vessel is not in keeping with the general purpose and intent of this code.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; r. and recr. Register, February, 1971, No. 182, eff. 3-1-71; am. (1) (b), (i) and (j), Register, May, 1974, No. 221, eff. 6-1-74; r. and recr. Register, May, 1978, No. 269, eff. 6-1-78.

Ind 41.22 Preparation for internal inspection. The owner or user of a boiler or a pressure vessel subject to inspection shall prepare the vessel for internal inspection after due notice from the inspector. To prepare a vessel for an internal inspection all manhole plates, all wash-out plugs, and a sufficient number of handhole plates to permit a satisfactory inspection shall be removed. The shell and heads shall be thoroughly cleaned and exposed when so requested. Each steam boiler shall be thoroughly drained of water and all fire side surfaces cleaned before an internal inspection is made.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; r. and recr. Register, February, 1971, No. 182, eff. 3-1-71.

Ind 41.23 Insurance company inspections. (1) Periodic inspections of boilers and pressure vessels by insurance companies may be accepted by the department under the following conditions:

(a) The boiler and pressure vessel inspectors employed by the insurance company shall hold certificates of competency issued by the department.

(b) The insurance company shall report inspections of boilers and pressure vessels to the department as required in section Ind 41.26.

(c) The inspection procedures used by the insurance company shall conform to the regulations of this code.

(d) The insurance company shall report to the department within 30 days when insurance coverage is started or discontinued on a boiler or pressure vessel. The reason for discontinuing the coverage shall be given on the report.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; r. and recr. Register, February, 1971, No. 182, eff. 3-1-71; am. (1) (a), (b) and (d), Register, May, 1974, No. 221, eff. 6-1-74.

Ind 41.24 Inspections by cities. (1) Periodic inspections of boilers and pressure vessels by cities of the first class may be accepted by the department under the following conditions:

(a) The boiler and pressure vessel inspectors employed by the city shall hold certificates of competency issued by the department.

(b) The city shall keep a record of such periodic inspections and shall submit a copy to the department.

(c) The inspection procedures used by the city shall conform to the regulations of this code.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; r. and recr. Register, February, 1971, No. 182, eff. 3-1-71; am. (1) (a) and (b), Register, May, 1974, No. 221, eff. 6-1-74.

Register, May, 1978, No. 269
Boiler and Pressure Vessel Code

Ind 41.25 Companies or corporations allowed to make inspections. (1) Periodic inspections by companies or corporations of boilers or pressure vessels which they own or operate may be accepted by the department under the following conditions:

(a) The boiler and pressure vessel inspectors employed by the company or corporation shall hold certificates of competency issued by the department.

(b) The company or corporation shall report inspections of boilers and pressure vessels to the department as required in section Ind 41.26.

(c) The inspection procedures used by the company or corporation shall conform to the regulations of this code.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; r. and rec. Register, February, 1971, No. 182, eff. 3-1-71; am. (1) (a) and (b), Register, May, 1974, No. 221, eff. 6-1-74.

Ind 41.26 Reporting of inspections. (1) Reports of periodic internal or external inspections of boilers and pressure vessels shall be sent to the department within 15 days from the date of inspection.

(2) External inspections shall be reported only when either of the following conditions is found:

(a) An internal inspection is not possible because of the construction of the vessel. In such cases the first inspection shall be reported to the department in the same manner as an internal inspection. The report shall be marked "external" and the reason for making an external inspection instead of an internal shall be given.

(b) When violations of this code or unsafe conditions involving the safety of the vessel are found. This report shall be made on ASME Form P-6 and shall explain the violation or unsafe condition with references to code section numbers. A copy of the recommendations to the owner or user of the vessel shall accompany the report to the department.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; am. (1), Register, February, 1971, No. 182, eff. 3-1-71; am., Register, May, 1974, No. 221, eff. 6-1-74.

Ind 41.27 Inspection report forms. (1) An internal or external boiler inspection that conforms to periodic inspection requirements (Ind 41.20) shall be reported to the department on inspection form SB 210 or National Board of Boiler and Pressure Vessel Inspectors standard form.

(2) A pressure vessel inspection that conforms to periodic inspection requirements (Ind 41.20) shall be reported to the department on inspection form SB 209 or National Board of Boiler and Pressure Vessel Inspectors standard form.

(a) **Multiple Vessels on a Single Report.** A group of pressure vessels of the same design and use that are interconnected or are operated so as to form a unit, machine, or apparatus may be included in a single report. The report shall contain the number, description, and use of the vessel and shall be reported to the department on inspection form SB 209 or National Board of Boiler and Pressure Vessel Inspectors standard form.

Register, May, 1978, No. 289
Boiler and Pressure Vessel Code

DEPT. OF INDUSTRY, LABOR & HUMAN RELATIONS 18-1

(3) The inspection report shall be legible and complete as possible. A manufacturer's data report of boiler or pressure vessel shall be available to inspector for first inspection.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; r. and recr. Register, February, 1971, No. 182, eff. 3-1-71; am. (1) and (2), Register, May, 1974, No. 221, eff. 6-1-74.

Ind 41.28 Certificates of operation. (1) After each periodic internal or external inspection a certificate of operation shall be issued to the owner or user of the boiler or pressure vessel by the department or by the city authorized by that agency.

(2) The certificate of operation shall give the maximum operating pressure as determined using the regulations of the code.

(3) The certificate of operation shall be valid until the next required periodic inspection.

(4) The certificate of operation shall be kept on file on the premises by the owner or user of the boiler or pressure vessel and shall be available when called for by a deputy of the department.

Note: See Wis. Adm. Code chapter Ind 69, Fee Schedule, for amount of fee to be paid to the department for all certificates of operation.

History: Cr. Register, April, 1961, No. 64 eff. 5-1-61; am. (1), (4) and (6), Register, January, 1968, No. 121, eff. 2-1-68; am. (1), (2), (3) and (4) and r. (5), Register, October, 1970, No. 178, eff. 11-1-70; am. (1) and (4), Register, May, 1974, No. 221, eff. 6-1-74.

Ind 41.29 Condemnation. (1) The condemnation of a boiler or pressure vessel shall be a function of the department only. Any boiler or pressure vessel declared by an authorized inspector to be unsafe and beyond repair shall be referred to the department for condemnation proceedings.

(2) Any boiler or pressure vessel confirmed by the department to be unsafe for further use shall be stamped as follows:

"CONDEMNED"

"Arrowhead Stamp x Wisconsin x Arrowhead Stamp"

Letters shall be at least $\frac{3}{8}$ " high and arrowheads shall be $\frac{1}{2}$ " wide.

(3) It shall be unlawful for any person, firm, partnership or corporation to use, operate, or offer for sale for operation within the state any condemned boiler or pressure vessel.

History: Cr. Register, October, 1970, No. 178, eff. 11-1-70; am. (1) and (2), Register, May, 1974, No. 221, eff. 6-1-74.

**PART IV
NUCLEAR POWER PLANTS**

Ind 41.30 Installation registration. (1) **OWNER REPORT FILING BEFORE OPERATION.** The owner of any nuclear class pressure vessel within the scope of ASME code section III, except as regulated in section Ind 41.21, shall file a copy of form N-3, ASME data report, with the department before operating the pressure vessel.

(2) **REGISTRATION OF PRESSURE VESSELS, BOILERS AND POWER PIPING.** All other pressure vessels, boilers and power piping at nuclear power plants must be registered with the department as required by section Ind 41.06.

Register, May, 1978, No. 269
Boiler and Pressure Vessel Code

The installation inspection shall meet the requirements of section Ind 41.14.

Note: Large groups of vessels may be reported in summary form in lieu of individual reports for each vessel.

History: Cr. Register, May, 1978, No. 269, eff. 6-1-78.

Ind 41.35 Periodic inspections. (1) **IN-SERVICE INSPECTION PROGRAM.** The owner or user shall place on file with the department an in-service inspection plan as required by section XI of the ASME code listed in table 41.10-A. The department shall be notified at least 10 days prior to all planned shutdowns which include in-service inspections.

Note: A copy of the in-service inspection plan accepted by the Nuclear Regulatory Commission will be acceptable to the department in satisfying the filing of an in-service inspection plan required by the code.

(2) **STATEMENT OF INSPECTION SERVICE CONTRACT.** The owner or user shall file a statement with the department indicating possession of an arrangement with an authorized inspection agency to provide inspection services under section XI of the ASME code listed in table 41.10-A. The statement must include the name and address of the current authorized inspection agency.

(3) **IN-SERVICE INSPECTION REPORT.** Within 90 days after each in-service inspection, the owner or user shall submit an owner's data report for in-service inspection (NIS-1) describing the inspections performed under section XI of the ASME code listed in table 41.10-A.

(4) **FREQUENCY OF INSPECTION.** Pressure vessels located within a nuclear containment may be inspected as part of the in-service inspection. The vessels shall be inspected at least once every 36 months.

Note: Extension of period between inspections. If operating conditions require, longer periods between inspections may be approved by the department upon receipt of a written request for an extension.

History: Cr Register, May, 1978, No. 269, eff. 6-1-78.

Ind 41.40 Welded repair. (1) **RECORD OF REPAIR.** The owner or the owner's agent shall furnish the department, within 90 days, a record of repair (form SB-190) when any component within the scope of ASME code section XI (table 41.10-A) is repaired by welding.

Note #1: No other supporting documents are required to be submitted to meet this requirement.

Note #2: Multiple repairs to the same object may be reported on a single report form.

(2) **RECORD OF MODIFICATIONS, REPLACEMENT, ADDITIONS OR ALTERATIONS.** When modifications, replacements, additions or alterations are made by welding, the requirement stated in (1) shall apply.

(3) **EXEMPTION.** Piping, valves and fittings of 2-inch nominal pipe size and smaller are exempt from the requirements of this section.

History: Cr. Register, May, 1978, No. 269, eff. 6-1-78.

Ind 41.45 Report of incidents. The owner or the owner's agent shall report to the department any incident involving pressure-retaining components within the scope of section XI of the ASME code (table 41.10-A) which requires notification to the U.S. nuclear regulatory commission.

Register, May, 1978, No. 269
Boiler and Pressure Vessel Code

DEPT. OF INDUSTRY, LABOR & HUMAN RELATIONS 18-3

The report shall be filed coincident with the report to the U.S. nuclear regulatory commission.

Note: It is the intent of the department to avoid conflicts with the requirements of the U.S. Nuclear Regulatory Commission.

**PART V
NEW INSTALLATIONS
ORIGINAL CONSTRUCTION**

Ind 41.50 ASME code vessels. Except as regulated in Wis. Adm. Code sections Ind 41.51, Ind 41.52 and Ind 41.53, boilers and pressure vessels installed after the effective date of this section shall be constructed and installed in accordance with the ASME standards adopted under section Ind 41.10 (1) (a).

Note: The department will recognize the applicable "case interpretations" of ASME Boiler and Pressure Vessel Code as being acceptable.

History: Cr. Register, April, 1961, No. 84, eff. 5-1-61; r. and recr. Register, December, 1962, No. 84, eff. 1-1-63; am. Register, August, 1964, No. 104, eff. 9-1-64; am. Register, January, 1966, No. 121, eff. 2-1-66; am. Register, March, 1966, No. 123, eff. 4-1-66; r. and recr., Register, November, 1970, No. 179, eff. 12-1-70; am. (1) Intro. par., Register, March, 1971 No. 183, eff. 4-1-71; r. and recr., Register, May, 1974, No. 221, eff. 6-1-74; am. Register, May, 1978, No. 269, eff. 6-1-78.

Ind. 41.51 Wisconsin special vessels. (1) Where it is not possible or practical to construct a boiler or pressure vessel in strict compliance with section Ind 41.50, the department may grant a modification to the owner or user to permit the installation of the vessel as a Wisconsin special within the state of Wisconsin under the following conditions:

(a) When the method of designing or constructing the vessel is not covered by the ASME codes listed in section Ind 41.10, the department may approve the installation of the vessel if adequate proof of comparable safety of the design or construction is shown.

1. Complete plans, calculations, and specifications in duplicate shall be submitted to and approved by the department before the vessel is installed.

2. The vessel shall be stamped "Wisconsin Special".

3. All other applicable requirements of the ASME codes listed in section Ind 41.10 shall be met.

(b) When the vessel is to be built by an owner for the owner's use, the department may waive the stamping required by the ASME codes listed in section Ind 41.10.

1. Complete plans, calculations, and specifications in duplicate shall be submitted to and approved by the department before the vessel is installed.

2. The vessel shall be stamped "Wisconsin Special".

3. All other applicable requirements of the ASME codes listed in section Ind 41.10 shall be met.

(c) When a small number of vessels is to be built by a manufacturer, the department may waive the stamping required by the ASME codes listed in section 41.10.

Register, May, 1978, No. 269
Boiler and Pressure Vessel Code

18-4 WISCONSIN ADMINISTRATIVE CODE

1. Complete plans, calculations, and specifications in duplicate shall be submitted to and approved by the department before the vessel is installed.

2. The vessel shall be stamped "Wisconsin Special".

3. All other applicable requirements of the ASME codes listed in section Ind 41.10 shall be met.

(2) The provisions of this section shall not apply to Wisconsin special vessels accepted by the department before the effective date of this section.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; r. and recr., Register, February, 1971, No. 182, eff. 3-1-71; r. and recr., Register, May, 1974, No. 221, eff. 6-1-74.

Ind 41.52 U.S. department of transportation—federal highway division. Pressure vessels carrying the stamping of the D.O.T. will be considered comparable to a vessel meeting the requirements of section Ind 41.50. When such vessels are used in the state of Wisconsin, it shall be the responsibility of the owner of the vessels to have the construction records of the vessels available for inspection by the department.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; am. Register, February, 1971, No. 182, eff. 3-1-71; am., Register, May, 1974, No. 221, eff. 6-1-74.

Ind. 41.53 Non-code vessels. (1) The following vessels are not required to be constructed and installed in accordance with the codes listed in table 41.10-A, but shall meet the pressure-relief device requirements of the ASME codes listed in table 41.10-A. Pressure-temperature relief devices listed by AGA, UL or ASME satisfy the requirements for pressure-relief devices when installed on water heaters and hot water storage tanks connected to water heaters with heat inputs not exceeding 200,000 Btu per hour and temperatures not exceeding 210 ° F.

(a) Water heaters used exclusively for hot water service, provided such apparatus meets the requirements of nationally recognized standards (ANSI, AGA or UL) listed below, or ASME, or as approved by the department. Stamping of water heaters or hot water storage tanks with applicable AGA, UL or ASME stamp constitutes evidence of conformance with this code. Water heaters or hot water storage tanks not so stamped shall:

1. Have their design submitted for approval by the department;
2. Withstand a hydrostatic pressure of 300 psi or their rated hydrostatic test pressure if greater than this amount without developing leakage or permanent distortion; and
3. Be equipped with suitable primary (flame safeguard) safety controls, limit switches and burners, or electric elements as required by a nationally recognized standard, such as those listed below.

Note: Conformance with the following standards will be considered as compliance with (1) (a):

ANSI C 33.87-1972, Safety Standard for Household Electric Storage-Tank Water Heaters (UL-174, 47th edition and revisions 10/15/73, 4/17/74, 9/12/74, 2/5/75 and 9/8/76). (Note: Limited to 600 volts, 12 kw and 1-120 gallons.)

ANSI Z 21.10.1-1975, American National Standard for Gas Water Heaters, Volume I, Automatic Storage Type Water Heaters with Inputs of 75,000 Btu per Hour or Less. (AGA Z 21.10.1-1975)

Register, May, 1978, No. 269
Boiler and Pressure Vessel Code

DEPT. OF INDUSTRY, LABOR & HUMAN RELATIONS 18-5

ANSI Z 21.10.3-1975, American National Standard for Gas Water Heaters, Volume III, Circulating Tank, Instantaneous and Large Automatic Storage Type Water Heaters. (AGA Z 21.10.3-1975)

ANSI Z 95.3-1975, Safety Standard for Oil-Fired Storage Tank Water Heaters (UL-732, 3rd edition and revisions 6/6/75 and 10/3/75). (Note: Limited to 200,000 Btu per hour (60 kw), 120 gallons and 200 ° F.)

(b) Vessels for containing water under pressure for domestic supply including those having an air space for expansion.

(c) Hot water storage tanks, when heated indirectly by circulating either steam at or below 15 psig, or by hot water at or below 30 psig through a coil or heat exchanger, and the storage water temperature does not exceed 210 °F.

(d) Pressure vessels used for water conditioning and filtration.

(e) The vessels listed in paragraphs (b), (c) and (d) of this section shall be identified by stamping showing the manufacturer's name, a serial number, the allowable working pressure, and the year fabricated.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; am. (1) (intro. par.) and (1) (a), Register, May 1974, No. 221, eff. 6-1-74; am. (1) (c) and r. and recr. (1) (intro.) and (a), Register, May, 1978, No. 269, eff. 6-1-78.

Ind 41.54 Multi-boiler installation. (1) HOT WATER HEATING BOILERS. When hot water heating boilers are installed in multiples with a common header and a common return, isolation valves may be eliminated between units and they may be considered one boiler provided:

(a) No single unit exceeds 500,000 Btu per hour output;

(b) Each unit has a pressure-relief device as required by the ASME code listed in table 41.10-A or the common header has a pressure-relief device(s) with sufficient relieving capacity for all units in the installation.

(c) Each unit has operating controls and safety controls acceptable to the department; and

(d) The fuel supply to each unit is shut off by a low water cutoff in the event of low water in the system.

History: Cr. Register, April, 1961, No. 64, eff. 5-1-61; r. and recr. Register, May, 1978, No. 269, eff. 6-1-78.