

analysis. The soil-bearing values of common soils may be determined through soil identification.

Note: The department will accept the soil-bearing values for the types of soil listed in the following table:

Type of soil	PSF
1. Wet, soft clay; very loose silt; silty clay .....	2,000
2. Loose, fine sand; medium clay; loose sandy clay soils .....	2,000
3. Stiff clay; firm inorganic silt .....	3,000
4. Medium (firm) sand; loose sandy gravel; firm sandy clay soils; hard dry clay .....	4,000
5. Dense sand and gravel; very compact mixture of clay, sand and gravel ....	6,000
6. Rock.....	12,000

(a) *Minimum soil-bearing values.* If the soil located directly under a bearing or foundation overlies a layer of soil having a smaller allowable bearing value, the smaller soil-bearing value shall be used.

(b) *Unprepared fill material, organic material.* No footing or foundation shall be placed upon unprepared fill material, organic soil, alluvial soil or mud unless the load will be supported. When requested, soil data shall be provided.

Note: The decomposition of organic material in landfill sites established for the disposal of organic wastes may produce odorous, toxic and explosive concentrations of gas which may seep into buildings through storm sewers and similar underground utilities unless provisions are taken to release the gases to the atmosphere.

History: Cr. Register, November, 1979, No. 287, eff. 6-1-80.

**ILHR 21.16 Frost penetration.** Footings and foundations, including those for ramps and stoops, shall be placed below the frost penetration level, but in no case less than 48 inches below the ground. Footings shall not be placed over frozen material.

(1) **EXCEPTIONS.** (a) Floating slabs constructed on grade need not be installed below the minimum frost penetration line provided measures have been taken to prevent frost forces from damaging the structure.

(b) Grade beams need not be installed to the minimum frost penetration line provided measures are taken to prevent frost forces from damaging the structure.

(c) Stoops or ramps need not be installed below the minimum frost penetration level provided measures are taken to prevent frost forces from damaging the structure.

(d) Footings or foundations may bear directly on rock located less than 42 inches below grade. Prior to placement, the rock shall be cleaned of all earth. All clay in the crevices of the rock shall be removed to the level of frost penetration or 1-½ times the width of the rock crevice. Provisions shall be taken at grade to prevent rain water from collecting along the foundation wall of the building.

History: Cr. Register, November, 1979, No. 287, eff. 6-1-80; am. (intro.), Register, February, 1985, No. 350, eff. 3-1-85.

**ILHR 21.17 Drain tiles.** (1) **WHERE REQUIRED.** Drain tiles or pipe shall be provided around footings located in soils where ground water levels occur above the elevation of the footing.

Register, May, 1988, No. 389

(a) *Municipalities exercising jurisdiction.* Municipalities exercising jurisdiction under chs. ILHR 20 to 25 may determine the soil types, natural and seasonal groundwater levels for which drain tile is required.

(b) *All other areas.* Drain tiles shall be required whenever a soil test shows evidence of periodic or seasonal saturation at any depth less than 72 inches. When the on-site evaluation shows no evidence of saturation, drain tiles need not be installed. Under all other conditions, drain tiles shall be installed on each side of foundation walls at the footing level.

(2) **MATERIALS AND INSTALLATION REQUIREMENTS.** (a) Drain tiles or pipes used for foundation drainage shall be at least 3 inches inside diameter.

(b) Where individual tiles are used, they shall be laid with  $\frac{1}{8}$ -inch open joints. Joints between the tiles shall be covered with a strip of sheathing paper or asphalt or tar saturated felt.

(c) The tile or pipe shall be placed upon at least 2 inches of washed rock and shall be covered with at least 12 inches of washed rock which meets the following criteria:

1. 90-100% of the rock must pass a  $\frac{3}{4}$ -inch sieve; and
2. 20-25% of the rock must pass a  $\frac{3}{8}$ -inch sieve.

(d) The basement slab shall be placed on at least 4 inches of gravel.

(e) Bleeder tiles shall be provided to connect the exterior footing drain tile to the interior footing tile and shall be placed in the footing such that the tiles are spaced at 8 foot intervals.

(f) The drain tiles or pipe shall be laid at a grade of not less than  $\frac{1}{8}$  inch per foot leading to the sump pit.

(3) **DRAIN TILE DISCHARGE.** Drain tiles shall be connected to a sump pit. The sump shall discharge to natural grade or be equipped with a pump to discharge water away from the dwelling via surface drainage channels.

(a) *Sumps.* 1. **Construction and installation.** The sump shall have a rim extending at least one inch above the floor immediately adjacent to the sump, except where the sump is installed in an exterior meter pit. The sump shall have a removable cover of sufficient strength for anticipated loads. The sump shall have a solid bottom.

2. **Location.** All sumps installed for the purpose of receiving clear water, basement or foundation drainage water shall be located at least 15 feet from any water well.

3. **Size.** The size of each clear water sump shall be as recommended by the sump pump manufacturer, but may not be smaller than 16 inches in diameter at the top, 14 inches in diameter at the bottom and 22 inches in depth.

(b) *Sump pump systems.* 1. **Pump size.** The pump shall have a capacity appropriate for anticipated use.

2. **Discharge piping.** Where a sump discharges into a storm building drain or sewer, a free flow check valve shall be installed.

(4) **SUMP DISCHARGE DISPOSAL.** (a) *Storm sewer.* Storm water, surface water, groundwater and clear water wastes shall be discharged to a storm sewer system or a combined sanitary-storm sewer system where available. Combined public sanitary-storm sewer systems shall be approved by the department of natural resources. Combined private sanitary-storm sewer systems shall be approved by the department.

(b) *Other disposal methods.* 1. Where no storm sewer system or combined sanitary-storm sewer system is available or adequate to receive the anticipated load, the storm water, surface water, groundwater and clear water wastes shall be discharged in accordance with local governmental requirements.

2. Where approved by the local governmental authority, storm water, surface water, groundwater and clear water wastes of the properties of one- and 2-family dwellings may be discharged onto flat areas, such as streets or lawns, so long as the water flows away from the buildings and does not create a nuisance.

(c) *Segregation of wastes.* 1. a. Except as provided in subd. 3., where a sanitary sewer system and a storm sewer system are available, the drain piping for storm water or clear water wastes may not connect to any part of the sanitary drain system.

b. Where a combined sanitary-storm sewer system is available, storm water wastes, clear water wastes and sanitary wastes may not be combined until discharging to the building sewer.

2. Storm water wastes and clear water wastes may not be combined until discharging into the storm building drain.

3. The clear water wastes from a refrigerated drinking fountain, water heater or storage tank relief valve or water softener shall be discharged to either a sanitary drain system or a storm drain system.

Note: Subsections (3) (a) and (4) are excerpts from the state uniform plumbing code, s. ILHR 82.36.

History: Cr. Register, November, 1979, No. 287, eff. 6-1-80; r. and recr. Register, February, 1985, No. 350, eff. 3-1-85; r. and recr. (3) (a) 3. and (4), Register, May, 1988, No. 389, eff. 6-1-88.

#### Subchapter V—Foundations

**ILHR 21.18 Foundations.** Foundation walls shall be designed and constructed to support the vertical loads of the dwelling, lateral soil pressure, and other loads without exceeding the allowable stresses of the materials of which the foundations are constructed.

(1) **CONCRETE FOUNDATION WALLS.** Unless designed through structural analysis, the minimum thickness of concrete foundation walls shall be determined from Table 21.18-A, but in no case shall the thickness be less than the thickness of the wall it supports.

Register, May, 1988, No. 389

TABLE 21.18-A  
CONCRETE WALL THICKNESSES

Type of Concrete	Nominal Thickness (inches)	Maximum Height of Unbalanced Fill <sup>1</sup> for Material of Wall Being Supported (Wood frame - feet)
3000 psi Unreinforced concrete	6	6.5
	8	8
	10	9
	12 <sup>2</sup>	10
	14	11.5

<sup>1</sup>Unbalanced fill is the difference in elevation between the outside grade and the basement floor.

<sup>2</sup>The maximum height of unbalanced fill for a 12-inch thick plain concrete wall may be increased to 12 feet provided the wall is constructed of concrete with a minimum compressive value of 6,000 psi at 28 days.

(2) **MASONRY FOUNDATION WALLS.** Unless designed through structural analysis, the masonry foundation walls shall be constructed in accordance with the following requirements:

(a) *Unreinforced masonry wall; thickness.* The minimum thickness of unreinforced masonry foundation walls shall be determined by Table 21.18-B, but in no case shall the thickness be less than the thickness of the wall it supports.

(b) *Reinforced masonry wall; thickness.* Reinforced masonry walls shall be reinforced in accordance with the requirements of Tables 21.18-C and 21.18-D. In partially reinforced masonry walls, vertical reinforcement shall be provided on each side of any opening, at each wall corner, and at intervals indicated in the tables.