

1. Pressure vessels used for water conditioning and filtration are exempt from relief valve requirements when connected to municipal water mains and when there is no check valve between such vessels and the water main.

(b) Constructed by qualified welders employed by a manufacturer registered with the commission, and designed with a safety factor of four and an allowable working pressure of at least 100 psig.

(c) Identified by a stamp showing the manufacturer's name, a serial number, the allowable working pressure, and the year fabricated.

History: Cr. Register, December, 1956, No. 12, eff. 1-1-57; cr. (4) and (5), Register, May, 1958, No. 29, eff. 6-1-58; cr. (5) (a) 1, Register, July, 1959, No. 43, eff. 8-1-59.

Ind 41.52 Forms. The following forms are listed in accordance with Sec. 227.013, Wis. Stats. They are issued by the Safety & Building Division and may be obtained from the Industrial Commission, 1 West Wilson Street, Madison.

(1) SB-14 Insurance Company Boiler Inspector (Ind 41.08).

(2) SB-37 Application For A Certificate Of Competency (Ind 41.08).

(3) SB-39 Manufacturer's Data Report of Boiler or Pressure Vessel (Ind 41.09).

History: Cr. Register, October, 1957, No. 22, eff. 11-1-57.