some part of its distributing system, whereby graphic records of the water pressure in such part of the system, continuous for each consecutive 24-hour period, shall be automatically made. Such records shall show the time and date of both beginning and ending, and shall be preserved on file in the office of the utility for a period of not less than 3 years following their respective dates.

PSC 185.08 Fire service. Each water utility furnishing fireprotection, as well as domestic and industrial, service, shall, unless exempted by the commission from the necessity of furnishing fire streams direct from hydrants, be prepared on short notice to make such increase in the normal pressure and volume of water delivered as may be required for reasonably adequate fire protection and other simultaneous service throughout the system.

PSC 185.09 Pumpage records. (1) A permanent record shall be kept of the amount of water pumped into the distributing-pipe system each day, and the amounts pumped daily shall be summarized by months, and such daily records and summaries kept on file.

(2) For measuring pumpage, station meters are recommended as much more reliable and satisfactory than the simple pump stroke, or revolution, counter.

METERS

PSC 185.10 Initial accuracy. Before initial installation every new meter shall be tested by the utility for accuracy of registration, and no meter whose accuracy of registration does not fall within the following limits of allowable error shall be placed in service:

	Allow	able	
${f Meter}$	Error 2%		Allowable
Size	Plus or minus		Error 10%
(Diam. of	on Rates of Flow		(Under-registration)
Connection,	(Gals. per Min.)		on Flow of
Inches)	\mathbf{From}	${f To}$	(Gals. per Min.)
5/8 "	1	20	1/4
3/4 "	2	35	1/2
1"	3	60	3/4
1½"	5	100	$1\frac{1}{2}$
2"	8	160	2
3"	16	320	4
4"	28	560	7
6"	48	960	12

PSC 185.11 Maintenance of accuracy. The accuracy of registration of all meters in service shall be maintained, and shall be insured, by periodic retests of such frequency as the conditions of service in any case may warrant. Retests should include a test on a small and definite rate of flow within the range for which the allowable error is 2%.

PSC 185.12 Complaint test. Every water consumer or utility patron shall be entitled to have his meter retested by the utility at any time upon his conditional deposit of \$2 per inch of nominal size or fraction thereof, and such deposit shall be returned to him by the

utility in case the retest shall show the meter to be over-registering by more than 2%; otherwise, it shall be forfeited to the utility by the depositor. Such retest on request of a consumer shall be made in his presence, if desired by him.

History: 1-2-56; Am. Register, May 1956, No. 5. Eff. June 1, 1956.

PSC 185.13 Referee tests. Any water consumer may have official test of his meter made by this commission upon request, accompanied by a deposit of a meter-test fee of \$4 per inch of nominal size or fraction thereof, and upon payment of meter-transportation expense, if any. In such case, the meter-test fee deposited by the consumer will be refunded to him by the utility furnishing the metered service in question if the meter be found by the commission to be over-registering beyond the allowable limit of error for new meter as stated in section PSC 185.10.

History: 1-2-56; Am. Register, May 1956, No. 5. Eff. June 1, 1956.

PSC 185.14 Meter records. A permanent record shall be kept of the tests on each meter, and such records shall show the name, number and size of the meter, date and place of the original and of each subsequent installation, and the complete results of each test and retest. The records shall also show the cause of each removal from service and what, if any, repairs were made between time of removal and the retest of the meter. The original test record shall show the identification of the meter and all data taken in form that permits convenient checking of the methods employed and the calculations. Any meter that has been in service for a period of 2 years, for which no satisfactory record is available, shall be tested, and a permanent record made within 1 year from the date of this order unless this time is extended by written order of the commission.

PSC 185.15 Equipment. Each water utility furnishing service to any of its patrons on the meter basis shall provide and maintain suitable working space and equipment or apparatus satisfactory to the commission for the testing and repairing of meters. Meter-testing equipment shall at all reasonable hours be accessible for inspection and use by the authorized representatives of the commission.

PSC 185.16 Portable test meters. Where portable test meters are used to determine the accuracy of meters in service, they shall be frequently recalibrated by suitable testing apparatus to insure safe reliance upon them for correct registration at the specified test rates of flow.

PSC 185.17 Billing. Bills rendered periodically for metered water service shall designate the readings of the meter at the beginning and end of the interval for which the bill is rendered, and shall give the dates of the readings of the meter.

PSC 185.18 Construction records. Every water utility shall prepare, or cause to be prepared, and shall keep on file, permanent and adequate records, in the form of maps or clearly descriptive tabular statements, or both, showing the size, kind and location of all its underground main- and service-pipe lines or other hidden construction, and definite locations of all valves and shutoff cocks. For all new construction work done after January 1, 1920, the records shall also show date of construction, by year and month.

Register May, 1956, No. 5