

**Chapter NR 665**

**APPENDIX III**

**EPA INTERIM PRIMARY DRINKING WATER STANDARDS**

Parameter	Maximum level ( mg/L)
Arsenic . . . . .	0.05
Barium . . . . .	1.0
Cadmium . . . . .	0.01
Chromium . . . . .	0.05
Fluoride . . . . .	1.4–2.4
Lead . . . . .	0.05
Mercury . . . . .	0.002
Nitrate (as N) . . . . .	10
Selenium . . . . .	0.01
Silver . . . . .	0.05
Endrin . . . . .	0.0002
Lindane . . . . .	0.004
Methoxychlor . . . . .	0.1
Toxaphene . . . . .	0.005
2,4–D . . . . .	0.1
2,4,5–TP Silvex . . . . .	0.01
Radium . . . . .	5 pCi/L
Gross Alpha . . . . .	15 pCi/L
Gross Beta . . . . .	4 millirem/yr
Turbidity . . . . .	1/TU
Coliform Bacteria . . . . .	1/100 ml

**Note:** Turbidity is applicable only to surface water supplies.