

Chapters SPS 361 to 366

APPENDIX A

The material contained in this appendix is for clarification purposes only and is numbered to correspond to the number of the rule as it appears in the text of the code.

A-361.03 (5) (b) Lower thresholds for municipalities with preexisting stricter sprinkler ordinances. Section 101.14 (4m) (d) and (e), Stats., provides the following thresholds above which fire sprinkler protection or 2-hour fire-resistance can be required by a municipality with a preexisting stricter sprinkler ordinance.

| Class of Construction | Total Floor Area Within Individual Dwelling Units | Number of Units | Total Floor Area of Nondwelling Unit Portions (Common use areas, such as corridors, stairways, basements, cellars, vestibules, community rooms, laundry rooms, pools, etc.) |
|--|---|-----------------|---|
| Type IA | 8,000 sq ft | 8 units | 12,000 sq ft |
| Type IB | | | 10,000 sq ft |
| Type IIA | | | 8,000 sq ft |
| Type IIB Type III Type IV Type VA | | | 5,600 sq ft |
| Type VB | | | 4,800 sq ft |

The Department, based on ordinances forwarded by municipalities (and checked by Industry Services staff for conformance with the preexisting sprinkler ordinance criteria), or based on other provided information, believes the following municipalities have preexisting stricter sprinkler ordinances. Other municipalities may also have preexisting stricter sprinkler ordinances.

Appleton
Brookfield
Franklin
Greendale
Greenfield

Madison
Menomonee Falls
Monona
Mount Pleasant

Muskego
New Berlin
Oak Creek
Racine

Shorewood Hills
Sussex
Thiensville
West Allis
West Bend