

Chapter Comm 66

APPENDIX

The material contained in this Appendix is for clarification purposes only and is numbered to correspond to the number of the rule as it appears in the text of the code.

A-66.04 (1) (c) Lower thresholds for municipalities with preexisting stricter sprinkler ordinances. Section 101.14 (4m) (d) and (e), Stats., provides the following thresholds above which fire sprinklers or two-hour fire resistance can be required by a municipality with a preexisting stricter sprinkler ordinance.

Class of Construction	Total Floor Area Within Individual Dwelling Units	Number of Units	Total Floor Area of Nondwelling Unit Portions (Common use areas, such as corridors, stairways, basements, cellars, vestibules, community rooms, laundry rooms, pools, etc.)
Type 1 – Fire resistive Type A	8,000 sq ft.	8 units	12,000 sq ft.
Type 2 – Fire Resistive Type B			10,000 sq ft.
Type 3 – Metal Frame Protected			8,000 sq ft.
Type 4 – Heavy Timber Type 5A – Masonry Protected Type 5B – Masonry Unprotected			5,600 sq ft.
Type 6 – Metal Frame Unprotected Type 7 – Wood Frame Protected			4,800 sq ft.
Type 8 – Wood Frame Unprotected			

The department believes the following municipalities have a preexisting stricter sprinkler ordinance:

Appleton	Greenfield	Muskego	Shorewood Hills
Brookfield	Madison	New Berlin	Sussex
Franklin	Menomonee Falls	Oak Creek	West Allis
Greendale	Monona	Racine	West Bend